Verification No.: VLS2A25071402EGDE03

Date of issue: 2025-09-22

Applicant:	Efficient Energy Technology GmbH
	Annenstraße 23 8020 Graz Austria

Device Category: Inverter

Device Type: Storage Inverter

PGM categories:

□ Typ B □ Typ C □ Typ D

Model(s): SM-30-B0

Trademark: SolMate

Technical data: Product family: 800W

(For further details see A.2 Technical data of the power generating unit(s) on p.2)

Firmware version: 0.2.4-rf24

Grid connection code: [1] VDE-AR-N 4105:2018-11

Power generation systems connected to the low-voltage distribution network.

Technical minimum requirements for the connection to and parallel operation

with low voltage distribution networks.

with low-voltage distribution networks.

Testing standard: [2] DIN VDE V 0124-100(VDEV0124-100):2020-06

Grid integration of power generation systems-low voltage

Test requirements for power generation units to be connected and operated parallel with the low-voltage distribution networks

The above-mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.

- Setting values and disconnect times
- Properly functioning functional chain "NS-protection -interface switch"
- Technical requirements of the switching device
- Integrated interface switch that can also be used in conjunction with a central interface protection relay (VDE-AR-N 4105:2018-11, 6.4.1)
- Active detection of unintended islanding
- Single-fault tolerance

The certificate contains the following information:

- Technical specifications of the NS protection and corresponding power generation types
- Setting values of the protection functions
- Trip values of the protection functions

Test report no.: [3] LS2A25071402EGDE03

This verification confirms that the above-mentioned generating unit(s) with corresponding software meet the requirements of the referenced grid connection code at the time the tests were conducted.

This certificate relates to type testing and does not imply LYNS's endorsement, approval, certification or on-going control of the product(s), either in terms of performance, design, manufacture or materials used. This certificate and the results stated herein relate solely to the sample product(s) tested and to the specific tests undertaken.

The certificate will remain valid for the stated period providing no changes are made to the product, production method etc. This certificate is only valid when this is also found at http://www.lyns-tci.com/en/certificate-search or contact Lyns-tci Technology Guangdong Co., Ltd..

This certificate is for the exclusive use of LYNS's Client and is provided pursuant to "La area" ent between LYNS and its Client. LYNS's responsibility and liability are limited to the terms and conditions of the agreement. LYNS as umes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expens to large on the large of the large of

Jack Shi

Sr. Project Manager



Annex to the Verification No.: VLS2A25071402EGDE03

A.1 Revision history of the certificate

Rev. No.	Date	Changes	Status
0 (VLS2A25071402EGDE02)	2025-09-22	Initial issue	Active

A.2 Technical data of the power generating unit(s)

Model/Type reference:	SM-30-B0			
PV Input				
Rated Voltage [V]	51.2			
Capacity	: 2,304KWh (2,560KWh,90%DOD)			
Battery Type	LiFePO ₄			
Firmware version of the BMS	72			
AC Output				
Nominal output AC voltage [V]	230 (L + N + PE, 50/60Hz)			
Nominal Output Current [A]	3.48			
Nominal output power [W]:	800			
Max. apparent output power [VA]:	880			
Nominal input power [W]:	2500			
Nominal input Current [A]	: 10.9			
Software version	0.2.4-rf24			
Operating temperature range	-20°C ~ +55°C			
Degree of protection	IP65 (according to IEC 60529)			
Protection class	I (according to IEC 62109-1)			
Type of internal transformer	internal transformer (transformer)			
Firmware version	0.2.4-rf24			
Manufacturer	Hamedata Technology Co.,Limited 1-3F &; 6-8F, BLDG#A, Changfang Industrial Park, No.2 Guihua 5th Road, Pingshan District, Shenzhen, Guangdong, China			
Testing laboratory	Lyns-tci Technology Guangdong Co., Ltd. Room 1201, Unit 2, Building 18, No. 7, Science and Technology Boulevard, Houjie Town, Dongguan City, Guangdong, 523960 P.R. China (Accredited acc. ISO/IEC 17025: A2LA Accreditation no. 5200.02)			
Testing location	Same as above			
Date(s) of performance of tests	2025-07-22 to 2025-09-21			



Annex to the Verification No.: VLS2A25071402EGDE03

A.3 E.6 and E.7 Requirements for the test report for the NS protection

NS protection as integrated NS protection					
Type of grid and plant protection:	integrated NS protection				
Integrated interface switch:	Type of switching equipment: Relay: HF140FF-G				
Protection function	Setting value	Trip value	Disconnection time ^a		
Voltage drop protection U <	184.0 V	183.1 V	3.043 s		
Voltage drop protection U <<	103.5 V	102.9 V	0.330 s		
Rise-in-voltage protection U>	253.0 V	257.7 V	475 s ^b		
Rise-in-voltage protection U>>	287.5 V	287.6 V	0.152 s		
Frequency decrease protection f<	47.50 Hz	47.47Hz	0.149 s		
Frequency increase protection f>	51.50 Hz	51.52 Hz	0.134 s		

^aProper time of interface switch 10 ms

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms. A check of the overall functional chain "NS protection - interface switch" resulted in a successful disconnection.

The above-mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test).

The above-mentioned NS protection meet the reauirements for synchronization.

^bLongest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.5.7 Protectiordevices and protection settings of VDE 0124-100